



OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department, Regional Laboratory, Kota
Test Report (Chemical Examination of Water)

No. Lab./Tech./Chem./2024-25/ 789

Date:- 27.6.24


To,
Principal
St. Mary's Convent School
Ramganjmandi, Kota

District- Kota

Reference No./Date- N.M./27.06.2024
Date of Receipt- 27.06.2024

Sample taken by- Ashok

Source	Permissible Value as per IS : 10500/2012		RO Water
Location			School Campus
Village/Town/City			Ramganjmandi
Date of Collection			27.06.2024
Date of Examination			28.06.2024
Sample No	Desirable Limit	Permissible limit in absence of alternate Source	PC-69
Note:- All results except pH are in mg/l.			
pH	6.5 to 8.5	No relaxation	7.04
Turbidity(NTU)	1	5	0.24
Colour	5	15	-
Odour	Agreeable	Agreeable	-
Total Alkalinity (as CaCO ₃)	200	600	40
Total Hardness (as CaCO ₃)	300	600	48
Chloride (as Cl ₂)	250	1000	32
Nitrate (as NO ₃)	45	45	0.66
Fluoride (as F ₂)	1.0	1.5	0.1270
Total Dissolved Solids	500	2000	179


Senior Chemist
PHED Reg. Laboratory Kota


No. Lab./Tech./Chem./2024-25/

Date:-

Copy To

I. Chief Chemist, PHED Rajasthan, Gandhi Nagar, Jaipur

Senior Chemist
PHED Reg. Laboratory Kota


MANAGER
ST. MARY'S CONVENT SCHOOL
RAMGANJMANDI (KOTA)


PRINCIPAL
St. Mary's Convent School
Ramganj Mandi, KOTA



St. Mary's Convent Sec. School, Ramganjmandi

Affiliated to Central Board of Secondary Education, New Delhi

Address: Suket Road, Near Mariam Hospital, Ramganjmandi-326519 Dist. Kota (Raj)

Phone No.- 8306726651 E-mail: stmarysrma@gmail.com, web: www.stmarysramganjmandi.co.in

Affiliation No. 1730305 School Code: 10648

Date:- 29/06/2024

To Whomsoever it May Concern

This is to inform you that safe drinking water and sanitary condition certificate is in process.


PRINCIPAL
St. Mary's Convent School
Ramganj Mandi, KOTA